


No. F.6/DFS/MS/School/2020/SZ/190

Dated: 14/05/2020

FIRE SAFETY CERTIFICATE

Certified that the K.S. Memorial Public School located at Ghitorni, New Delhi-110047, comprised of ground plus two upper floor was issued NOC by this department vide letter No. F6/DFS/MS/School/SZ/2016/1848 Dated 28/12/2016. The premises was inspected by the officer concerned of this department on 19/03/2020 in the presence of Mrs. Jagwanti Lohia (Principal) of the school and found that said premises have deemed complied with fire prevention and fire safety arrangements in accordance with Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi, and that the school building is fit for occupancy class "Education Building" Group-B, as above with effect from 14/05/2020 for period of Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/05/2020 at New Delhi by



(S.S. Tuli)

Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Principal, K.S. Memorial Public School, Ghitorni, New Delhi-110047
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

